

Accessory for strips 3NJ41 In-line fuse switch disconnectors Sz. NH00 Current transformers can be integrated 150/5 A, Cl. 0.5 legal-for-trade calibrated



Figure similar

Model		
product brand name	SETRON	
product designation	Current transformer	
design of the product	accessory for fuse switch disconnecter 3NJ41	
operating voltage	0.72 kV	
insulation voltage rated value	3 kV	
designation of overcurrent limiting factor	FS 5	
current		
• at input rated value	150 A	
value range of the operating frequency	50/60 Hz	
Protection class		
protection class IP	IP20	
Mechanical Design		
height	60 mm	
width	46 mm	
depth	19 mm	
Net Weight	235 g	
Environmental conditions		
ambient temperature during operation		
• minimum	-10 °C	
• maximum	55 °C	
Approvals Certificates		
Environment	General Product Approval	other

[Environmental Confirmations](#)



[Confirmation](#)



[Confirmation](#)

other



### Further information

Information on the packaging

<https://support.industry.siemens.com/cs/ww/en/view/109813875>

Information for data generation and storage

<https://support.industry.siemens.com/cs/ww/en/view/109995012>

Information- and Downloadcenter (Catalogs, Brochures,...)

<https://www.siemens.com/lowvoltage/catalogs>

Industry Mall (Online ordering system)

<https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3NJ4915-1FB11>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<https://support.industry.siemens.com/cs/ww/en/ps/3NJ4915-1FB11>

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

[https://www.automation.siemens.com/bilddb/cax\\_en.aspx?mlfb=3NJ4915-1FB11](https://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3NJ4915-1FB11)

CAX-Online-Generator

<https://www.siemens.com/cax>

Tender specifications

<https://www.siemens.com/specifications>

Characteristic curves

[https://curves.simaris.siemens.com/curves/<mmp\\_prod\\_noCOMP="HAUPT"></mmp\\_prod\\_no>](https://curves.simaris.siemens.com/curves/<mmp_prod_noCOMP=)

---

last modified:

6/13/2025 

