



Figure similar

Low-Power Voltage sensor 3,25 Volt/Radical 3 at 20 kV/ Radical 3 according IEC 61869-11, for asymmetrical T-connector with C-cone (short version), e.g. for Nexans (K)430TB, nkt CB24-xxx, Südkabel SET24 und SAT24, Cellpack CTS 630 A 24kV, Tyco RSTI-58XX and RSTI-CC 58XX T-connectors accuracy class: 0,5 (FCM V3.30 onwards), else 1, Insulation level: 24/50/125 kV, Voltage factor: 1,2\*Un and 1,9\*Un for 8 h, with connection cable 2,0 m open end

### Further information

**Siemens is working on the renewal of the current EAC certificates.**

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

**Information- and Downloadcenter (catalogues, leaflets,...)**

<https://www.siemens.com/energy-automation>

**Industry Mall (Online ordering system)**

<https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=6MD2320-0AA07-1AB0>

**Service&Support (Manuals, Certificates, Characteristics, FAQs,...)**

<https://support.industry.siemens.com/cs/ww/en/ps/6MD2320-0AA07-1AB0>

**Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)**

[https://www.automation.siemens.com/bilddb/cax\\_en.aspx?mlfb=6MD2320-0AA07-1AB0](https://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=6MD2320-0AA07-1AB0)

**Tender specifications**

<https://www.siemens.com/specifications>

**Power Academy - Your training and consulting partner in the area of power transmission and distribution**

<https://www.siemens.com/poweracademy>

