

Technical Information

FieldPort SWA50

Intelligent Bluetooth® and/or WirelessHART adapter for all HART field devices



Application

The FieldPort SWA50 converts the HART signal of the connected HART field device to a reliable and encrypted Bluetooth® or WirelessHART signal. The FieldPort SWA50 can be retrofitted to all 2-wire and 4-wire HART field devices in both hazardous and non-hazardous areas. The robust stainless steel housing allows the FieldPort SWA50 to be installed even in harsh industrial environments.

The combination of the Bluetooth® version of the SWA50 with a FieldEdge SGC200 provides fast and easy connection to the Netilion Cloud and supports the use of data in various Netilion Services.

The WirelessHART version of the SWA50 can be easily integrated into any WirelessHART network.

Your benefits

- Reliable transmission of the measured process values through the connected FieldPort SWA50 via encrypted Bluetooth® or WirelessHART communication
- Easy to retrofit all 2-wire or 4-wire HART field devices
- Easy connection of all HART field devices to the Netilion Cloud
- Loop-powered adapter, without affecting the process signal
- Easily accessible, wireless, diagnostic information of connected HART field device

Table of contents

About this document	3	Accessories	16
Symbols	3	Device-specific accessories	16
Function and system design	3	Supplementary documentation	18
Function	3	Standard documentation SWA50	18
System architecture of the FieldPort SWA50		Supplementary device-dependent documentation for	
Bluetooth version	4	SWA50	18
System architecture of the FieldPort SWA50		Standard documentation for SGC200	18
WirelessHART version	5	Standard documentation for SGC500	18
Input (wired interface)	5	Standard documentation for SMT70	18
Inputs	5	Standard documentation for SMT77	18
Communication interface and protocol version	5	Standard documentation for SWA70	18
Output (wireless interface)	5	Standard documentation for SWG70	19
Communication interface	5	Registered trademarks	19
Transmission frequency band	6	Radio approvals	19
Range	6	Europe	19
Transmission power	6	Canada and United States	19
Device variables	7	Japan	20
Diagnostics	7	Thailand	20
Power supply	7	Indonesia	20
Electrical connection	7	Singapore	21
Terminal assignment	9	South Korea	21
FieldPort SWA50 grounding	10		
Supply voltage	10		
Power consumption	11		
Terminals	11		
Cable entry	11		
Cable specification	11		
Mounting	11		
Mounting methods	11		
Mounting instructions	12		
Lightning protection	13		
Environment	13		
Ambient temperature range	13		
Storage temperature range	13		
Climate class	13		
Degree of protection	13		
Vibration resistance	13		
Shock resistance	13		
Electromagnetic compatibility (EMC)	13		
Mechanical construction	14		
Design, dimensions	14		
Weight	15		
Materials	15		
Display and user interface	15		
Operating concept	15		
Local operation	15		
Certificates and approvals	16		

About this document

Symbols

Safety symbols

DANGER

This symbol alerts you to a dangerous situation. Failure to avoid this situation will result in serious or fatal injury.

WARNING

This symbol alerts you to a dangerous situation. Failure to avoid this situation can result in serious or fatal injury.

CAUTION

This symbol alerts you to a dangerous situation. Failure to avoid this situation can result in minor or medium injury.

NOTICE

This symbol contains information on procedures and other facts which do not result in personal injury.

Symbols for certain types of information

Symbol	Meaning
	Permitted Procedures, processes or actions that are permitted.
	Preferred Procedures, processes or actions that are preferred.
	Forbidden Procedures, processes or actions that are forbidden.
	Tip Indicates additional information.
	Reference to documentation
	Reference to page
	Reference to graphic
	Visual inspection

Function and system design

Function

The FieldPort SWA50 converts the HART signal of the connected HART field device to a reliable and encrypted Bluetooth® or WirelessHART signal. The FieldPort SWA50 can be retrofitted to all 2-wire or 4-wire HART field devices.

With the Endress+Hauser SmartBlue app and the Endress+Hauser Field Xpert, you have the following capabilities:

- Configuration of the FieldPort SWA50
- Visualization of the measured values of the connected HART field device
- Visualization of the current combined status, consisting of the status for the FieldPort SWA50 and the status of the connected HART field device

HART field devices can be connected to the Netilion Cloud via the FieldPort SWA50 and a FieldEdge device.



Detailed information on Netilion Cloud: <https://netilion.endress.com>

The WirelessHART version of the FieldPort SWA50 can be integrated into a WirelessHART network via the Endress+Hauser WirelessHART Fieldgate SWG70 or via any compatible WirelessHART

gateway. More information is available from your Endress+Hauser sales organization:
www.addresses.endress.com.

In addition, the WirelessHART version can be operated as follows:

- Local configuration with FieldCare SFE500 or DeviceCare via DTM for FieldPort SWA50
- Remote configuration with FieldCare SFE500 via WirelessHART Fieldgate SWG70 and DTM for FieldPort SWA50 and Fieldgate SWG70


NOTICE

Safety applications with control functions via Bluetooth signal or WirelessHART signal

Undesirable behavior of safety application

- Do not use a wireless signal such as Bluetooth or WirelessHART in a safety application with a control function.

System architecture of the FieldPort SWA50 Bluetooth version




A0040482

1 System architecture of SWA50 Bluetooth version

- 1 HART field device with FieldPort SWA50, remote mounting
- 2 Encrypted wireless connection via Bluetooth®
- 3 HART field device with FieldPort SWA50, direct mounting
- 4 FieldEdge SGC200
- 5 LTE connection
- 6 Netilion Cloud
- 7 Application Programming Interface (API)
- 8 https Internet connection
- 9 Internet browser-based Netilion Service app or user application
- 10 Endress+Hauser SmartBlue app
- 11 Endress+Hauser Field Xpert, e.g. SMTxx

System architecture of the
FieldPort SWA50
WirelessHART version



2 System architecture of SWA50 WirelessHART version

- 1 Endress+Hauser Field Xpert, e.g. SMTxx
- 2 Host application / FieldCare SFE500
- 3 Ethernet communication
- 4 WirelessHART-Fieldgate, e.g. SWG70
- 5 FieldEdge SGC500
- 6 https Internet connection
- 7 Netilion Cloud
- 8 Application Programming Interface (API)
- 9 Internet browser-based Netilion Service app or user application
- 10 Endress+Hauser SmartBlue app
- 11 Encrypted wireless connection via Bluetooth®
- 12 HART field device with FieldPort SWA50, direct mounting
- 13 HART field device with WirelessHART adapter, e.g. SWA70
- 14 Encrypted wireless connection via WirelessHART
- 15 HART field device with FieldPort SWA50, remote mounting

Input (wired interface)

Inputs	A point-to-point connection to a 2-wire or 4-wire HART field device
Communication interface and protocol version	Field devices with HART 5, HART 6 or HART 7

Output (wireless interface)

Communication interface	Bluetooth Bluetooth IEEE 802.15.1
	 In addition to the FieldPort SWA50, there can be only one other HART master in the HART loop of the SWA50.


WirelessHART

- WirelessHART communication interface (IEC 62591)
- HART version 7.5, backward-compatible with previous HART versions

Transmission frequency band 2.4 GHz (ISM band)

Range  The range depends on the alignment of the FieldPort SWA50, the mounting location and the environmental conditions.

As the antenna of the WirelessHART gateway or FieldEdge is normally aligned vertically, we also recommend mounting the FieldPort SWA50 vertically. If the antennas are aligned differently, this can greatly reduce the antenna range.



 3 Different ranges depending on the position of the transmission window

Bluetooth

Up to 40 m without obstacles when FieldPort SWA50 is optimally aligned

WirelessHART

Up to 200 m without obstacles when FieldPort SWA50 is optimally aligned

Transmission power 0 dBm or 10 dBm, configurable for adaptation to national regulations

Device variables

	SmartBlue app	Field Xpert
Endress+Hauser field devices	- Measured value output current of HART field device - Device information, configuration data and HART information of the FieldPort SWA50 - Measured values PV, SV, TV and QV of HART field device - Additional device information of HART-7- or HART-6 field device - HART information of HART field device - Combined NAMUR NE 107 status, consisting of the status for the FieldPort SWA50 and the status of the connected HART field device	- Measured value output current of HART field device - Device information, configuration data and HART information of the FieldPort SWA50 - Measured values PV, SV, TV and QV of HART field device - Additional device information of HART-7- or HART-6 field device - HART information of HART field device - Combined NAMUR NE 107 status, consisting of the status for the FieldPort SWA50 and the status of the connected HART field device
Field devices of other manufacturers	- Measured value output current of HART field device - Device information, configuration data and HART information of the FieldPort SWA50	- Measured value output current of HART field device - Device information, configuration data and HART information of the FieldPort SWA50 Additionally in the livelist - Measured values PV and SV - Combined NAMUR NE 107 status, consisting of the status for the FieldPort SWA50 and the status of the connected HART field device



If the HART field device does not support the extended device status according to NAMUR NE 107, limitations may apply to the display of status information.

The following data can be read out via the Bluetooth version of the FieldPort SWA50 and the Endress+Hauser FieldEdge SGC200 (Netilion Services):

- Process variables PV and SV of HART field device if available
- Combined status according to NAMUR NE 107 of the FieldPort SWA50 and the HART field device, if available

For the WirelessHART version of the FieldPort SWA50 and the Endress+Hauser FieldEdge SGC500 (Netilion Cloud)



For detailed information, see the Operating Instructions of the FieldPort SWA50 WirelessHART → 18

Diagnostics

1 LED

Green: Flashes four times at start-up to indicate that the device is operational

The LED is located on the electronic insert and is not visible from the outside.


Power supply

Electrical connection

2-wire HART field device with passive current output



Some grounding concepts require shielded cables. If connecting the cable shield to the FieldPort SWA50, you must use a cable gland for shielded cable. See ordering information.




A0040494

4 Electrical connection for 2-wire HART field devices with passive current output (optional grounding not shown)

- 1 Supply voltage (SELV, PELV or Class 2) or PLC with active current input or transmitter with active current input
- 2 Electronic insert SWA50
- 3 2-wire field device 4 to 20 mA-HART

4-wire HART field device with passive current output

i Some grounding concepts require shielded cables. If connecting the cable shield to the FieldPort SWA50, you must use a cable gland for shielded cable. See ordering information.




A0040491

5 Electrical connection for 4-wire HART field devices with passive current output (optional grounding not shown)

- 1 Supply voltage (SELV, PELV or Class 2) or PLC with active current input or transmitter with active current input
- 2 Electronic insert SWA50
- 3 4-wire field device with passive 4 to 20 mA-HART output
- 4 Supply voltage for 4-wire field device

4-wire HART field device with active current output


i Some grounding concepts require shielded cables. If connecting the cable shield to the FieldPort SWA50, you must use a cable gland for shielded cable. See ordering information.



A0040492

6 Electrical connection for 4-wire HART field devices with active current output (optional grounding not shown) – PLC or transmitter at OUT terminals

- 1 Supply voltage (SELV, PELV or Class 2) for 4-wire HART field device
- 2 4-wire field device with active 4 to 20 mA-HART output
- 3 Electronic insert SWA50
- 4 PLC or transmitter with passive current input



A0045101


7 Electrical connection for 4-wire HART field devices with active current output (optional grounding not shown) – resistor at OUT terminals

- 1 Supply voltage (SELV, PELV or Class 2) for 4-wire HART field device
- 2 4-wire field device with active 4 to 20 mA-HART output
- 3 Electronic insert SWA50
- 4 Resistor 250 to 500 Ohm min. 250 mW between OUT+ and OUT- terminals

i If you select the "direct mounting" version and the "4-wire HART field device with active current output and PLC or transmitter" electrical connection version, you can use core cross-sections of 0.75 mm² at maximum. The wires that you insert into the shorter top housing section must be connected to the IN terminals opposite, and the wires that you insert into the longer bottom housing section must be connected to the OUT terminals opposite. If larger core cross-sections are required, we recommend remote mounting.

FieldPort SWA50 without HART field device

i With this connection version, you can preconfigure the FieldPort SWA50.




A0040493

8 FieldPort SWA50 without HART field device (optional grounding not showing)

- 1 Supply voltage of FieldPort SWA50, 20 to 30 VDC (SELV, PELV or Class 2)
- 2 Electronic insert SWA50
- 3 Resistor 1.5 kOhm and min. 0.5 W between terminals OUT+ and OUT-

Terminal assignment



A0040495

9 FieldPort SWA50 terminal assignment

- 1 Input terminal IN
- 2 Output terminal OUT

Application	Input terminal IN	Output terminal OUT
2-wire HART field device →  4,  8	Cable from supply voltage, PLC with active current output or transmitter with active current output	Cable to 2-wire HART field device
4-wire HART field device with passive current output →  5,  8	Cable from supply voltage, PLC with active current output or transmitter with active current output	Cable to 4-wire HART field device
4-wire HART field device with active current output →  8	Cable from 4-wire field device with active 4 to 20 mA HART output	PLC or transmitter with passive current output (optional), alternatively wire bridge between terminals OUT+ and OUT-
FieldPort SWA50 without field device →  8,  9	Cable from supply voltage for FieldPort SWA50	Resistor between terminals OUT+ and OUT-

FieldPort SWA50 grounding

"Direct mounting" version

With the "direct mounting" version, the FieldPort SWA50 is grounded via the field device or the metal conduit.

"Remote mounting" version

With the "remote mounting" version, ground the FieldPort SWA50 via the optional mounting bracket or a grounding clamp provided by the customer.

Optional mounting bracket


If using the mounting bracket, ground the FieldPort SWA50 via the grounding screw.

 Mounting bracket: →  16

Grounding clamp provided by customer

The grounding clamp provided by the customer must meet the following requirements:

- Diameter: approx. 40 mm
- Stainless steel
- If the FieldPort SWA50 is used in a hazardous area: suitable for hazardous areas as per DIN EN 62305, Sheet 3 and DIN EN 62561-1



A0041808

 10 Grounding via grounding clamp

1 Example of grounding clamp provided by customer

Supply voltage

- Loop-powered 4 to 20 mA
- 24 V DC (min. 4 V DC, max. 30 V DC): min. 3.6 mA loop current required for start-up
- The supply voltage or the power unit must be tested to ensure it meets safety requirements and the requirements for SELV, PELV or Class 2

Voltage drop

- If internal HART communication resistor is deactivated
 - 3.2 V in operation
 - < 3.8 V at start-up
- If internal HART communication resistor is activated (270 Ohm)
 - < 4.2 V at 3.6 mA loop current
 - < 9.3 V at 22.5 mA loop current




To select the supply voltage, pay attention to the voltage drop via the FieldPort SWA50. The remaining voltage must be high enough to enable the start-up and operation of the HART field device.

Power consumption	Max. 0.2 W at 22 mA and with internal HART communication resistor (270 Ohm)
Terminals	2 x 2-pin screw terminals
Cable entry	■ "Remote mounting" version: 2 cable glands ■ "Direct mounting" version: 1 cable gland and 1 direct cable entry from field device The following cable glands are available. ■ Plastic M20 for unshielded cable (only suitable for use in non-hazardous areas) ■ Brass M20 for unshielded cable ■ Brass M20 for shielded cable
Cable specification	Use cables that are suitable for the anticipated minimum and maximum temperatures. Observe grounding concept of the plant. 2 x 0.25 mm² to 2 x 1.5 mm² You can use unshielded cable with or without ferrules and shielded cable with or without ferrules.  If you select the "direct mounting" version and the "4-wire HART field device with active current output and PLC or transmitter" electrical connection version, you can use core cross-sections of 0.75 mm² at maximum. If larger core cross-sections are required, we recommend remote mounting.

Mounting


Mounting methods	■ Remote mounting ■ Direct mounting on HART field device via either M20 or NPT 1/2" connection adapter For remote mounting, we recommend the optional mounting bracket. Alternatively, you can secure the remote version using pipe clips.
-------------------------	---



A0043240

11 Example of remote mounting

- 1 HART field device
- 2 Cable
- 3 FieldPort SWA50 "remote mounting" version
- 4 Bottom housing section
- 5 Transmission window
- 6 Design ring
- 7 Top housing section



A0043241

12 Example of direct mounting

- 1 Cable
- 2 FieldPort SWA50 "direct mounting" version
- 3 HART field device
- 4 Bottom housing section
- 5 Transmission window
- 6 Design ring
- 7 Top housing section

Mounting instructions

- Pay attention to the alignment and range. → 6
- Observe a distance of at least 6 cm from walls and pipes. Pay attention to the expansion of the Fresnel zone.
- Avoid mounting in close proximity to high-voltage devices.
- Pay attention to the influence of vibrations at the mounting location. → 13

Additional mounting information for Bluetooth version:
Mount within the visual range of a FieldEdge SGC200.

Additional mounting information for WirelessHART version:
Mount within the visual range of a WirelessHART FieldPort, e.g. SWA50, SWA70, or a WirelessHART Fieldgate, e.g. SWG70.

Lightning protection

- Do not mount the FieldPort SWA50 at the highest point of the system.
- Ground the housing of the FieldPort SWA50.

Environment

Ambient temperature range -40 to +70 °C (-40 to +158 °F)

Storage temperature range -40 to +85 °C (-40 to +185 °F)

Climate class As per IEC 60068-2-38 test Z/AD

Degree of protection When housing is closed, tested according to:

- IP68 / NEMA 6P (24 h at 1 m under water)
- IP66 / NEMA 4X

Vibration resistance As per IEC 60068-2-64:2008

- $a(\text{RMS}) = 50 \text{ m/s}^2$
- $f = 5 \text{ to } 2000 \text{ Hz}$
- $t = 3 \text{ planes} \times 2 \text{ h}$

 Vibration resistance tested only for "remote mounting" version.


Shock resistance As per IEC 60068-2-27:2008
300 m/s^2 [= 30 gn] + 18 ms

Electromagnetic compatibility (EMC) Electromagnetic compatibility as per EN 61326 series and NAMUR recommendation EMC (NE 21)

Mechanical construction

Design, dimensions


"Remote mounting" version



13 Dimensions of "remote mounting" version in mm (in)


- 1 M20 cable gland
- 2 Transmission window

"Direct mounting" version



14 Dimensions of "direct mounting with M20" version in mm (in)

- 1 Connection adapter with M20 thread
- 2 Transmission window
- 3 M20 cable gland



A0043218

15 Dimensions of "direct mounting with NPT" version in mm (in)

- 1 Connection adapter with 1/2 NPT thread
- 2 Transmission window
- 3 M20 cable gland

Weight	Max. 500 g
Materials	Housing Stainless steel 1.4404 (316L) Cable glands Plastic or brass, depending on the version. See ordering information. Connection adapter ■ M20 thread: stainless steel. 1.4404 (316L) ■ NPT 1/2" thread: stainless steel. 1.4404 (316L) Seals ■ Design ring (housing – cover seal): PC ■ O-ring: EPDM ■ Transmission window seal: silicone

Display and user interface

Operating concept	The FieldPort SWA50 can be operated as follows: ■ Via a smartphone or tablet with the Endress+Hauser SmartBlue app ■ Via Endress+Hauser Field Xpert SMT7x tablet PC In addition, the WirelessHART version can be operated as follows: ■ Local configuration with FieldCare or DeviceCare via DTM for SWA50 ■ Remote configuration with FieldCare via WirelessHART-Fieldgate SWG70 and DTM for SWA50 and SWG70
Local operation	You can enable and disable the following functions via DIP switches. ■ Bluetooth communication ■ Firmware update ■ Configuration via Bluetooth

The DIP switches are located on the electronic insert.

Certificates and approvals

Current certificates and approvals that are available for the product can be selected via the Product Configurator at www.endress.com:

1. Select the product using the filters and search field.
2. Open the product page.
3. Select **Configuration**.

Accessories


Various accessories are available for the device, and can be ordered with the device or at a later stage from Endress+Hauser. Detailed information on the specific order code is available from your local Endress+Hauser sales organization or on the product page of the Endress+Hauser website: www.endress.com.

Device-specific accessories

Mounting bracket

Order number
71520242

Material
Stainless steel 1.4404 (316L)



A0043312

16 FieldPort SWA50 mounted via optional mounting bracket

- 1 Hexagonal-headed bolt for securing and grounding
- 2 Support bracket
- 3 Mounting bracket
- 4 Round bracket


Mounting and alignment options

The mounting bracket can be mounted as follows:

- On pipes with a maximum diameter of 65 mm
- On walls

The FieldPort can be aligned as follows using the support bracket:

- Via the various mounting positions on the mounting bracket
- By rotating the support bracket




A0043411

17 Alignment options via support bracket


- 1 Various mounting positions on support bracket
- 2 By rotating the support bracket

Dimensions



A0043313

18 Dimensions of mounting bracket – pipe mounting



A0043410

19 Dimensions of retaining bracket – wall mounting

Supplementary documentation

Standard documentation SWA50

Operating Instructions

- Bluetooth: BA01987S
- WirelessHART: BA02046S

Brief Operating Instructions

WirelessHART: KA01436S

Supplementary device- dependent documentation for SWA50

All explosion-protection data are provided in separate Ex documentation. The relevant Ex documentation is delivered with the Ex devices as standard. You can also find the Ex documentation via the Product Configurator → 16.

Standard documentation for SGC200

Technical Information

TI01468S

Operating Instructions

BA02058S

Standard documentation for SGC500

Technical Information

TI01525S

Operating Instructions

BA02035S

Standard documentation for SMT70

Technical Information

TI01342S

Operating Instructions

BA01709S

Standard documentation for SMT77

Technical Information

TI01418S

Operating Instructions

BA01923S

Standard documentation for SWA70

Technical Information

TI00026S

Operating Instructions

BA00061S

Standard documentation for
SWG70

Technical Information
TI00027S

Operating Instructions
BA00064S

Registered trademarks

Bluetooth®
Registered trademark of the Bluetooth Special Interest Group (SIG), Kirkland, Washington, USA

HART®
Registered trademark of the FieldComm Group, Austin, Texas, USA

WirelessHART®
Registered trademark of the FieldComm Group, Austin, Texas, USA

Radio approvals

Europe	This device meets the requirements of the "Radio Equipment Directive" (RED) 2014/53/EU: ■ EN 300 328 V2.1.1 ■ EN 301 489-1 V2.1.1 ■ EN 301 489-17 V3.1.1 ■ EN 62311: 2008
Canada and United States	FCC ID: LCGSWA50 IC: 2519A-SWA50 This device complies with Part 15 of the FCC Rules and with Industry Canada license-exempt RSS standard(s). Operation is subject to the following two conditions: ■ this device may not cause harmful interference, and ■ this device must accept any interference received, including interference that may cause undesired operation.  Changes or modifications made to this equipment not expressly approved by Endress+Hauser SE+Co. KG may void the FCC authorization to operate this equipment. This device has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures: ■ reorient or relocate the receiving antenna ■ increase the separation between the equipment and receiver ■ connect the equipment into an outlet on a circuit different from that to which the receiver is connected ■ consult the dealer or an experienced radio/TV technician for help with radiofrequency radiation exposure information. This equipment complies with FCC and IC radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with a minimum distance of 20 cm (7.87 in) between the radiator and your body. This transmitter must not be co-located or operating in conjunction with any other antenna or transmitter.

Changes or modifications made to this device that are not expressly approved by Endress+Hauser may void the FCC authorization to operate this device. This device must be installed to ensure a minimum antenna separation distance of 20 cm from all persons.

Français

Le présent appareil est conforme aux CNR d'industrie Canada applicables aux appareils radio exempts de licence.

L'exploitation est autorisée aux deux conditions suivantes :

- L'appareil ne doit pas produire de brouillage, et
- L'utilisateur de l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.



Les changements ou modifications apportées à cet appareil non expressément approuvée par Endress+Hauser SE+Co. KG peut annuler l'autorisation FCC d'utiliser cet appareil.

Déclaration d'exposition aux radiations

Cet équipement est conforme aux limites d'exposition aux rayonnements IC établies pour un environnement non contrôlé. Cet équipement doit être installé et utilisé avec un minimum de 20 cm (7.87 in) de distance entre la source de rayonnement et votre corps.

Ce transmetteur ne doit pas être placé au même endroit ou utilisé simultanément avec un autre transmetteur ou antenne.

Japan

電気通信事業法

Japanese Radio Law and Japanese Telecommunications Business Law Compliance.

This device is granted pursuant to the Japanese Radio Law (電波法) and the Japanese Telecommunications Business Law (電気通信事業法).

This device should not be modified (otherwise the granted designation number will become invalid).

Thailand

เครื่องโทรคมนาคมและอุปกรณ์นี้ มีความสอดคล้องตามข้อกำหนดของ กสทช.

(This telecommunication equipment is in compliance with NBTC requirements.)



A0046301

(This radio communication equipment is exempted from requiring a license, user license, or radio communication station license as per NBTC notification regarding radio communication equipment and radio communication station has been exempted from requiring a license according to radio communication act B.E.2498.)

Indonesia

Cert. ID: 78107/SDPPI/2021
PLG ID: 4962



A0047307

Singapore

Complies with
IDMA Standards
DA108204

A0042672

South Korea

방송통신기자재등의 적합등록 필증
(Registration of Broadcasting and Communication Equipments)
기자재명칭 (제품명칭) : 특정소출력 무선기기 (무선데이터통신시스템용 무선기기)
(Equipment code: LARN8 Registration No.: R-R-EH7-SWA50)
해당 기자재는 「전파법」 제58조의2 제3항에 따라 등록되었습니다.
(It is verified that foregoing equipment has been registered under the Clause 3, Article 58-2 of Radio Waves Act.)



www.addresses.endress.com
